

### **CERTIFICATE OF APPROVAL** No CF 5034

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

#### FISCHERWERKE GMBH & CO. KG.

Weinhalde 14-18, 72178 Waldachtal, Germany Tel: int+ 49 7443 120 Fax: int+ 49 7443 124222

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT

TECHNICAL SCHEDULE

FiAM - fischer Intumescent Acoustic Mastic

**TS40 Linear Gap Sealing Systems** 

Signed and sealed for and on behalf of CERTIFIRE

Sir Ken Knight

Chairman - Management Council

Issued: 23<sup>rd</sup> January 2012 Revised: 25<sup>th</sup> April 2012 Valid to: 10<sup>th</sup> April 2017

Page 1 of 3









## CERTIFICATE No CF 5034 FISCHERWERKE GMBH & CO. KG.

#### FiAM - fischer Intumescent Acoustic Mastic

- 1. This approval relates to the use of FiAM fischer Intumescent Acoustic Mastic for the fire protection of movement joints within walls and floors. The detailed scope is given in the Approval Matrix included in this Certificate. This shows the thickness and acceptable services for FiAM fischer Intumescent Acoustic Mastic .required to provide fire resistance periods in accordance with BS 476: Part 20: 1987 of up to 300 minutes for wall/floor constructions. The scope of this certification complies with the guidelines stated in the ASFP Redbook: 3<sup>rd</sup> Edition for 3<sup>rd</sup> party certification schemes.
- 2. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), Section 2 of the Technical Standards (Scotland), Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.'
- The product is approved on the basis of:
  - i) Initial type testing
  - ii) Audit testing at the frequency specified in TS40
  - iii) A design appraisal against TS40
  - iv) Inspection and surveillance of factory production control
- 4. The concrete walls shall be at least 150mm thick and the floors at least 230mm thick and have at least the same fire rating as that required for the penetration seal.
- 5. Masonry and concrete gap faces will be within the density range of 450 to 2300kg/m³, and gap faces will be free from loose or flaking material.
- 6. Backing or support materials may be polyethylene or polyurethane foam, mineral or ceramic fibre insulation.
- 7. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturers' name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

Further information regarding the details contained in this data sheet may be obtained from fischerwerke GmbH & Co. KG. (Tel: int+ 49 7443 120).

Further information regarding the CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 2 of 3 Signed

KJV ...

Issued: 23<sup>rd</sup> January 2016 Revised: 25<sup>th</sup> April 2012 Valid to: 10<sup>th</sup> April 2017



# CERTIFICATE No CF 5034 FISCHERWERKE GMBH & CO. KG.

FiAM – fischer Intumescent Acoustic Mastic - Approval Matrix

	nd Floor Installations - ct Name		FiAM - fi	scher	Intumescent Acous	tic Mastic		
Configuration		Max. Joint Width (mm)	Minim Seal De (mm	um epth	Backing Material	Integrity (mins)	Insulation (mins)	
Wall Constructions	Autoclaved aerated concrete/autoclaved aerated concrete	20	10		Polyethylene 30 mm diameter	300	300	
	Autoclaved aerated concrete/autoclaved aerated concrete	30	15		Polyethylene 40 mm diameter	300	210	
	Autoclaved aerated concrete/autoclaved aerated concrete	40	40 20		Polyethylene 50 mm diameter	300	210	
	Autoclaved aerated concrete/autoclaved	Autoclaved aerated 50 25			Polyethylene 60 mm diameter	300	210	
	Brick/Autoclaved aerated concrete	15	10		Polyethylene 20 mm diameter	240	0	
	Brick/autoclaved aerated concrete	25	10		Polyethylene 30 mm diameter	240	30	
	Steel/ aerated blockwork	30	15		Polyethylene 40 mm diameter	300	90	
	Steel/ aerated blockwork	50	25		Ethafoam 50 mm diameter	60	30	
	Hardwood/ aerated blockwork	50	25		Ethafoam 50 mm diameter	60	60	
	Softwood/ aerated blockwork	25	12		Ethafoam 30 mm diameter	30	30	
Floor Constructions	Aerated concrete/ aerated concrete	20	10		Polyethylene 30 mm diameter	300	120	
	Aerated concrete/ aerated concrete	30	15		Polyethylene 40 mm diameter	300	60	
	Aerated concrete/ aerated concrete	40	20		Polyethylene 50 mm diameter	300	60	
	Aerated concrete/ aerated concrete	50	25		Polyethylene 60 mm diameter	300	210 30	
	Softwood/ aerated concrete	25	12		Ethafoam 30 mm diameter	30	30	
	Hardwood/ aerated concrete	50	25		Ethafoam 50 mm diameter	60	60	
	Steel/ aerated concrete	50	25		Ethafoam 50 mm diameter			
Appli	cation Technique	or grease ar	nd be suital	surtac	es of the building elerned.			
Resistance to Smoke:		Not evaluated by this approval		Weather Capability:		Not evalu approval	Not evaluated by this approval	
Acoustic Rating:		R <sub>w</sub> 38 (-2;-7) in accordance with BS EN ISO 717-1: 1997		Movement Capability:		Not evalu approval	Not evaluated by this approval	

Page 3 of 3 Signed



Issued: 23<sup>rd</sup> January 2016 Revised: 25<sup>th</sup> April 2012 Valid to: 10<sup>th</sup> April 2017